

BERTHING SPRINKLER SYSTEM (MCM ONLY) CHECK SHEET
FOR USS _____
DATE: _____

REF: (A) PMS 5221/027
(B) NSTM 555 V1
(C) GSO 521

	IAW	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT
COMPARTMENT NUMBER												
A. INSPECT BERTHING SPRINKLING SYSTEM PIPING AND COMPONENTS:	5221/027											
1. Verify there is no leakage on the following components:	2W-1R											
a. Firemain supply root cutout valve?	2W-1R											
b. Sprinkling control valve?	2W-1R											
c. Sprinkler heads and piping?	2W-1R											
d. Pressure gage?	2W-1R											
e. Flow switch?	2W-1R											
f. Sprinkler line testers?	2W-1R											
g. Flush-out hose valve?	2W-1R											
h. Drain valve?	2W-1R											
2. Is the sprinkling control valve open?	2W-1R											
3. Ensure the fire main supply cutout valve is in the open position?	2W-1R											
B. INSPECT SPRINKLER HEADS:	5221/027											
1. Are the sprinkler heads free of paint, dust and dirt?	S-2R											
2. Is there any damage to the sprinkler heads, (broken arms or defectors)?	S-2R											
3. Is the glass bulb the right type?	GSO 521											
C. TEST FLOW SWITCH:	5221/027											
1. Did the flow switch activate in CCS?	R-1S											
2. Did the flow switch reset in CCS?	R-1S											

REMARKS:	

ASSESSOR(S): _____ DATE: _____